

RBC-SMCN61L Remote Controller ON/OFF Lock Lead

Description and Contents

The lead will allow the on off function of the remote to be locked in the on or off position.


Contents: Lead with Connector

Installation and Operating Instructions

Installation

The interface lead must be plugged into the CN61 connector on the indoor unit PCB.

When the Green and White leads are linked out the on/off button is locked in the on or off status. The operation of the on / off function will not be permitted by the button on the remote controller, whilst the leads are connected together.



For Technical Information Contact

TOSHIBA Air Conditioning

Tel: 0870 8430333